



## Equip. pour mât de lignes aériennes MT 6.9KA/1s

Internal Reference: SOFPATL-PCA25-4/2525



The main purpose of its installation is to protect the worker against accidental switching on or possible voltage feedback during repair work.

### Characteristics

I(n)	6,9 KA/1s A	Certification	IEC 61230
------	-------------	---------------	-----------